



Department of Management Studies

University of Kashmir

Hazratbal, Srinagar-190006

Ph.0194-2415554, Fax-0194-2415129

www.tbs.uok.edu.in, www.kashmiruniversity.net

I) Terms & Conditions for Air Conditioner (A. C. split)

1. Only the bidder having GST registration certificate are eligible.
2. The bidder ensure after sale service of the product.
3. The tender shall be accompanied with attested photo copies of GST Registration & authorized dealership certificates.
4. The tender shall be submitted with CDR of Rs. 10,000/- pledged in the name of Head, Department of Management Studies.
5. The rates shall be quoted both in figures & words, served with transparent tape, Signature with seal should be affixed on all pages of the tender documents duly covered with transparent tape.
6. Rates quoted should be inclusive of GST & other charges installation etc.
7. Conditional or incomplete tender shall be rejected.
8. Payment shall be made only after qualitative and quantitative verification by the Department.
9. The University reserves the right to negotiate the rates with the firms/dealers.
10. The University reserves the right to accept or reject in part or full any or all the bids without assigning any reason thereof.
11. The right to appeal shall be within the jurisdiction of Srinagar.
12. The tender for AC Hot & Cold Split should reach to the office of the Department of Management Studies by or before 20-8-2018 up-to 3.00Pm.

Signature with Stamp _____

Name of Proprietor _____

Name of the Firm _____

Address _____

Phone No: - _____

Mobile No: - _____

II) Specifications

S. No	Specifications	
1.	Product Name	Split Air Conditioner
2.	Make /Brand	Popular brands with standard accessories, preferably conforming to IS-1391 part-2
3.	Cooling capacity/Tonnage	1.5 Ton; 2.0 Ton (to be quoted separately)
4.	Type	Inverter/Non Inverter type (with star specification if applicable)
5.	Air Circulation	More than 500 Cu.Ft./Hour
6.	Noise level (indoor unit)	Less than 45 dB(at lowest speed)
7.	Refrigerant	R-134A/R-410 A/R -410
8.	Installation	Mounting/fitting of outdoor & indoor units at respective locations at the Department of Management Studies, as per standard procedure; with insulated copper refrigerant pipes and power cables (upto 20 feet each) & standard PVC drain pipes (upto 10 feet/20 feet).
9.	Voltage Stabilizer	Supply & installation of suitable wall mount automatic voltage stabilizer of popular brand/make with input voltage range of 90V-250V or better.
10.	Warranty	Five years on compressor/condenser; one year over all warranty.